

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7125-0476:135 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Harrington Signal Inc., 2519 4<sup>th</sup> Avenue, Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731

DESIGN: Models SSF015/75-24VWR, -24VWW, -24VCR, -24VCW; SSF030/75- 24VWR, -24VWW, -24VCR, -24VCW; SSF060/75-24VWR, -24VWW, -24VCR, -24VCW; SSF075-24VWR, -24VWW, -24VCR, -24VCW; SSF0110-24VWR, -24VWW, -24VCR, -24VCW; non-synchronized strobes; Models SSF015/75-24VWRS, -24VWWS, -24VCRS, -24VCWS; SSF030/75-24VWRS, -24VWWS, -24VCRS, -24VCWS; SSF060/75-24VWRS, -24VWWS, -24VCRS, -24VCWS; SSF075-24VWRS, -24VWWS, -24VCRS, -24VCWS; SSF0110-24VWRS, -24VWWS, -24VCRS, -24VCWS synchronized strobes. All synchronized strobes must be used with Faraday's Models 5405 and 5406 Sync Module. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: Electrical: 20-31 VDC; 120 VAC  
Candela: 15/75cd, 30/75cd, 60/75cd, 75cd, 110cd  
Flash Rate: 60 flashes/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed compatible audible signal devices and fire alarm control units. All units are suitable for wall or ceiling mounted. For indoor use only.

XLF: 7125-0065:154

04-14-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager